

NOTES:

BASIN SHALL HAVE ONE GRATING UNLESS OTHERWISE SPECIFIED ON IMPROVEMENT PLANS.

CONCRETE SHALL BE CLASS 560-C-3250 WHEN THE BASIN IS TO BE CONSTRUCTED WITHIN THE LIMITS OF A PROPOSED SIDEWALK OR IS CONTIGUOUS TO SUCH A SIDEWALK, THE TOP OF THE BASIN SHALL BE POURED MONOLITHIC WITH THE SIDEWALK, USING CLASS 560-C-3250 CONCRETE IN THE SIDEWALK. THE TOP OF THE CATCH BASIN SHALL BE FINISHED PER SIDEWALK STANDARDS.

CONNECTION PIPES MAY BE PLACED IN ANY POSITION AROUND THE WALLS, PROVIDED THEY POINT IN THE PROPER DIRECTION AND THE POSITION IS OTHERWISE CONSISTENT WITH THE IMPROVEMENT PLAN.

CURVATURE OF THE END-WALLS AT CURB OPENING SHALL BE FORMED BY CURVED FORMS AND SHALL NOT BE MADE BY PLASTERING.

DIMENSIONS:

GRATE SHALL BE PARALLEL TO PLANE OF GUTTER SLOPE.

t=6 INCHES IF H IS 8 FEET OR LESS.

t=8 INCHES IF H IS GREATER THAN 8 FEET AND LESS THAN 20 FEET.

H=3 FEET 6 INCHES, UNLESS OTHERWISE SPECIFIED ON IMPROVEMENT PLANS.

W=2 FEET 11 3/8 INCHES FOR ONE GRATING. ADD 3 FEET 5 3/8 INCHES FOR EACH ADDITIONAL GRATING.

EXPOSED SURFACES OF THE CATCH BASIN SHALL CONFORM IN SLOPE, GRADE, COLOR, FINISH, AND SCORING TO EXISTING IMPROVEMENTS ADJACENT TO THE BASIN. WHERE NO SIDEWALK EXISTS, THE TOP SHALL BE FINISHED TO CONFORM TO STANDARD SIDE-WALK SLOPE AND FINISH. WHERE NO CURB EXISTS, THE BATTER OF EXPOSED END WALLS ABOVE THE STREET SURFACE SHALL CONFORM TO BATTER FOR STANDARD CURB.

FLOOR OF BASIN SHALL BE GIVEN A STEEL-TROWELLED FINISH.

OUTLET PIPE SHALL BE TRIMMED TO THE FINAL SHAPE AND LENGTH BEFORE CONCRETE IS POURED.

REINFORCING STEEL SHALL BE NO. 4 DEFORMED BARS. CLEARANCE SHALL BE 1 1/2 INCHES FROM INSIDE OF BOX. SPACING IS AS SHOWN IN TOP SLAB AND AT 18 INCH CENTERS IN SIDES OF BOX.

SLOPE OF FLOOR PARALLEL WITH CURB SHALL BE 1 IN 12 UNLESS OTHERWISE SPECIFIED SLOPE FLOOR FROM ALL DIRECTIONS TO THE OUTLET.

STEPS: 3/4 INCH PLAIN ROUND GALVANIZED STEEL STEPS ARE REQUIRED AS FOLLOWS. (ALHAMBRA FDY. A-3320 OR EQUAL)

IF H IS 3.5 FEET OR LESS, NO STEPS ARE REQUIRED.

IF H IS MORE THAN 3.5 FEET, AND NOT MORE THAN 5.0 FEET, INSTALL ONE STEP 16 INCHES ABOVE FLOOR OF BASIN.

IF H IS MORE THAN 5.0 FEET, INSTALL STEPS 12 INCHES APART, WITH THE TOP STEP 6 INCHES BELOW THE TOP OF INLET.

ALL STEPS SHALL BE 4 INCHES CLEAR FROM THE WALL EXCEPT THE TOP STEP, WHICH SHALL BE 2 1/2 INCHES (CLEAR) FROM THE WALL AND ANCHORED NOT LESS THAN 5 INCHES IN WALL OF BASIN.

CITY OF MURRIETA
DEPARTMENT OF DEVELOPMENT SERVICES

REVISIONS		COMBINATION INLET CATCH BASIN SPECIFICATIONS	STD. NO.
3/97	APPROVED		405