



SECTION A-A

**DETAIL OF REINFORCEMENT
AROUND PIPE**

1. ALL REINFORCING SHALL BE # 4 BARS at 12" O.C. BOTH WAYS IN TOP SLAB AND WALLS.
2. CATCH BASIN SHALL BE CONSTRUCTED OF CLASS "A" CONCRETE.
3. CURB & GUTTER ADJOINING CATCH BASIN SHALL BE CONSTRUCTED PRIOR TO CONSTRUCTING TOP OF CATCH BASIN.

CITY OF ADELANTO

L.J.F. 12-74
SCD 9/84

RICHARD S. TITERA
CITY ENGINEER

TYPE "A"
CATCH BASIN

206