



DETAIL OF ANCHOR

NOTES

1. FLOOR OF BOX SHALL BE TROWLED SMOOTH.
2. IF THE TOE OF SLOPE IS ALLOWED WITHIN THE R/W, INLET TYPE 1 BEGINS AT THE TOE RATHER THAN AT THE R/W LINE.
3. FOR OPEN DITCH (TYPE 2), THE 24" (600 mm) EXTENSION BEYOND THE R/W LINE IS NOT REQUIRED WHEN BACK OF WALK IS 24" (600 mm) OR MORE FROM THE R/W LINE; HOWEVER, THE PARKWAY DRAIN SHALL EXTEND TO THE R/W LINE IN ANY EVENT.
4. TOP OF INLET STRUCTURE (TYPE 1 & 2) SHALL BE FLUSH WITH ADJACENT SURFACE WHERE PRACTICAL.
5. A HEADED STEEL STUD 5/8" x 6-3/8" WITH A 1" HEAD (16 x 160 mm, 25 mm HEAD) ATTACHED BY A FULL PENETRATION BUTT WELD MAY BE USED AS AN ALTERNATE ANCHOR.
6. NORMAL CURB FACE AT POINT M AND Q. CURB FACE IS B + 5" (125 mm) AT POINT N AND P.
7. THE 3" (75 mm) LEG OF THE 5/8" (16 mm) DIA ANCHORS SHALL BE PARALLEL TO THE TOP OF SIDEWALK.
8. J BARS ARE #3 (#10M).
9. FOR S = 48" (1200 mm) AND LESS, B = 3" (75 mm).
USE 2-1/2" x 2" x 3/8" (64 x 51 x 9.5 mm) GALVANIZED STEEL ANGLE.
10. FOR S = 54" (1350 mm) OR MORE, B = 4" (100 mm).
USE 3-1/2" x 3" x 1/2" (89 x 76 x 12.7 mm) GALVANIZED STEEL ANGLE.
11. ANGLE A EQUALS 90° UNLESS OTHERWISE SPECIFIED.