



ADJUSTMENT TO GRADE TYPICAL NEW INSTALLATION

NOTES:

1. Nut shaft extension, fitted with self-centering device and adaptor, by Pratt, or approved equal, shall be provided when cover over valve nut exceeds 2.5 feet.
2. If existing valve box is not a standard box, a box will be provided by the City and installed by the Contractor.
3. At no time shall the valve box rest directly on the valve body.

REVISED	DATE	APPROVED	CITY OF SANTA BARBARA - PUBLIC WORKS DEPARTMENT	STANDARD DETAIL
		<i>Anthony J. Howell</i>		
		PUBLIC WORKS DIRECTOR	VALVE BOX	6-004.0-06