



NOTES:

1. INSTALL FALL PREVENTION SYSTEM, OR SAFETY CAGE, WHERE HEIGHT OF LADDER EXCEEDS 20'-0". SEE A254
TYP
2. MINIMUM CLEARANCE TO ANY OBSTRUCTION ADJACENT TO LADDER: 2'-6" AT CLIMBING SIDE (2'-3" AT SMOOTH WALL) AND 1'-3" EACH SIDE OF CENTER LINE, AT SIDES OF LADDER.
3. COAT ALL AL SURFACES IN CONTACT WITH CONCRETE OR MASONRY, IN ACCORDANCE WITH THE SPECIFICATIONS.
4. WHERE GUARDRAIL IS SST, BOLT PIPE TO RAIL W/ 2- 1/2"Ø SST BOLTS.

A250
TYP **ALUMINUM LADDER FASTENED TO WALL**

08-01-05