



REVISIONS	
Δ 10-86 SW	

City of Hemet	
SIDEWALK DRAINAGE OUTLET THROUGH CURB	
Sheet 1 of 2	
STANDARD No. D - 308	

NOTES

1. All exposed steel shall be galvanized.
2. Reinforcing steel shall be embedded $1\frac{1}{2}$ diameters or 1" minimum clearance.
3. Grind off rough and sharp edges of exposed ends of plate covers.
4. $\frac{1}{2}$ " thk. galvanized steel plate cover with $\frac{1}{2}$ " diamonds to be a maximum of 3' wide x 6' long. Center supports will be required for any length exceeding these maximums.
5. See plans for curb elevations and dimensions.

REVISIONS	

City of Hemet
NOTES SIDEWALK DRAINAGE OUTLET THROUGH CURB
Sheet 2 of 2 STANDARD No. D - 308A