



- NOTES:
- 1- CLASS "B" CONCRETE TO BE USED. (5.0 SACK)
 - 2- TURN A BRICK ARCH OVER EVERY PIPE OPENING INTO MANHOLE
 - 3- CHANNEL HEIGHT TO BE EQUAL TO PIPE DIAMETER.
 - 4- BRICK IS TO BE WHOLE, SOUND, AND HARD BURNED AND MUST OTHERWISE CONFORM TO SUCH SPECIFICATIONS AS INDICATED BY THE CITY ENGINEER
 - 5- ALL PIPE DIAMETERS ("D") TO BE EQUAL.

CITY OF COLTON
PUBLIC WORKS DEPT.

DROP MANHOLE
BRICK CONSTRUCTION "Y" DROP
FOR TRUNK SEWERS, WHEN SPECIFIED.

DRAWN BY: T. FARKAS	SCALE: 1" = 3'-0"	DRAWING NO.
CHK'D: <i>[Signature]</i>	DATE: OCTOBER 1963	
APP'D: <i>[Signature]</i>		303