



NOTES:

1. REINFORCED PRE-CAST MANHOLES SHALL BEAR ASTM C-478 SPECIFICATIONS.
2. NON-REINFORCED PRE-CAST MANHOLES SHALL BE CLASS 5600-3250 PER SECTION 201 SS PWC.
3. THE DEPTH OF THE CHANNEL SHALL BE THE FULL DIAMETER OF THE PIPE.

CITY OF MONTCLAIR			
INSPECTION AND METERING MANHOLE			
DWN. BY D.G.	CKD. BY	APPROVED BY <i>Carl H. ...</i>	DATE 8/21/87
CITY ENGR. R.C.E. 20717			