



NOTES:

1. GRATE SHALL CONFORM TO REQUIREMENTS OF SECTION 75-1.02 OF CALTRANS STANDARD SPECIFICATION. GALVANIZING IS NOT REQUIRED.
2. ALL WELDS ON FRAME TO BE FULL PENETRATION DOUBLE V-GROOVE WELDS IN CONFORMANCE WITH AMERICAN WELDING SOCIETY STD. A-2.0.
3. LOCATE FRAME ANCHORS TO PROVIDE MINIMUM 2" CLEAR COVER.

REV.	DATE	DESCRIPTION

R:\Utilists\City_Stds_Details\Sewer_Drainage\S-40