



NOTES:

1. FOR STANDARD MANHOLE SEE STD. 505.
2. "X" VARIES BUT SHALL NOT BE LESS THAN 2' (61cm).
3. CONCRETE SHALL BE 560-C-3,2500 P.S.I., 4" (10.2cm) MAX. SLUMP.
4. ALL PIPES SHALL BE V.C.P..
5. THIS CONSTRUCTION METHOD REQUIRES CITY ENGINEER APPROVAL ON INDIVIDUAL BASIS.
6. ALL CONCRETE WORK SHALL BE FORMED.

DRAWN: WVN	DATE: 09/01/00
CHECKED: NSH	SCALE: N.T.S.
APPR.:	DATE:

DROP MANHOLE CONNECTION

DIRECTOR OF PUBLIC WORKS

CITY OF BUENA PARK

DWG. NO.: **STD. 507**