



TYPICAL SECTION
OF DROP INLET THROAT

STEP DETAIL

NOTE: FIRST RUNG SHALL BE MOUNTED NO GREATER THAN 12 INCHES BELOW THE TOP EXTERIOR OF THE DROP INLET.

REVISED	DATE	APPROVED	CITY OF SANTA BARBARA - PUBLIC WORKS DEPARTMENT	STANDARD DETAIL
		<i>Anthony Johnson</i>		
		PUBLIC WORKS DIRECTOR		
		1/31/07		2-003.0-06
		DATE		

