



- NOTES:**
1. PROVIDE WEEPHOLES WHERE WATER TABLE IS BELOW BOTTOM OF PIPE & AS DIRECTED BY OWNER, DO NOT WATERPROOF IF WEEPHOLES ARE PROVIDED.
 2. WATERPROOF OUTSIDE MANHOLE STRUCTURE WITH CRYSTALLINE AS MANUFACTURED BY PERMAQUIK OR APPROVED EQUIVALENT.
 3. TAPE WRAP ALL STEEL PER SPECIFICATIONS (OR AWWA C217 IF NOT SPECIFIED).

REVISION	DATE	BY	DESCRIPTION	CALLEGUAS MUNICIPAL WATER DISTRICT	STANDARD DRAWINGS	DWG NO
2	12/06	P&I	GENERAL		APPROVED Susan Mulligan MANAGER OF ENGINEERING	PVC PIPE MANHOLE ACCESS STRUCTURE
<small>Digitally signed by Susan Mulligan, DN: cn=Susan Mulligan, c=US Date: 2006.12.21 09:21:27 -0800</small> DATE THOUSAND OAKS CALIFORNIA						