

NOTES:

ALL JOINTS ABOVE THE LEACHING AREA SHALL BE MORTAR SEALED INSIDE AND OUT.

MAX. PERCOLATION RATE = 1"/HR, OR HALF OF AN ENGINEERED PERCOLATION TEST UP TO 5"/HR. MAX.

THE SURFACE AREA FOR PERCOLATION MAY BE THE OUTSIDE AREA OF THE GRAVEL (6.5' DIAM. TYP.)

THE HIGHEST RUNOFF FROM A 100 YEAR FREQUENCY STORM, NO MATTER WHAT TIME LENGTH, SHALL BE UTILIZED WHEN CALCULATING THE STORAGE CAPACITY NEEDED IN A DRYWELL.

THERE WILL CALCULATING THE STORAGE CAPACITY NEEDED IN A DIVINEEL.	
CITY OF RANCHO MIRAGE	STANDARD
PEVISIONS DRYWELL DETAIL	DETAIL
	306
APPROVED BY: CITY ENGINEER DATE	SHEET 1 OF 2

