



**SLEEVE POST DETAIL**

**NOTES:**

1. SIDEWALK BARRICADES SHALL BE PLACED ADJACENT TO BACK OF CURB. SIDEWALK SHALL BE PLACED ADJACENT TO CURB, AND CENTERED ON SIDEWALK WHEN SIDEWALK IS DETACHED FROM CURBS.
2. CONCRETE SHALL BE "CLASS A" SIX SACK
3. PLACE A R5-10c SIGN (2003 MUTCD DESIGN MANUAL CALIFORNIA SUPPLEMENT)
4. USE 1.5" DIAMETER NPS, GALVANIZED STANDARD PIPE
5. STEEL SLEEVE TO BE CONSTRUCTED WITH A 1/10" LARGER DIAMETER THEN POST. WALL THICKNESS OF SLEEVE TO BE SAME AS POST OR LARGER.
6. 3/8" DIAMETER GALVANIZED BOLT, WITH NUT AND WASHER. DEFORM THREADS (TYP)
7. DRILL 1/2" DIAMETERS HOLES. TOTAL OF 6
8. ALL SURFACES SHALL BE PAINTED WITH TWO COATS OF WHITE PAINT CONFORMING TO SECTION 91-3.02 OF THE STATE SPECIFICATIONS.

ROB JENSEN  
DIRECTOR OF PUBLIC WORKS/CITY ENGINEER

	DEPARTMENT OF PUBLIC WORKS
<h2>PEDESTRIAN BARRICADE</h2>	
SCALE: NONE REVISED: JANUARY 17, 2007 DRAWN BY: C KRAFT APPROVED BY: R JENSEN	<h3>ST-32</h3>