

## **NOTES**

- 1) SIZING PER UNIFORM PLUMBING CODE, CHAPTER 7, "TRAPS AND INTERCEPTORS".
- 2) THE UNIT SHOWN SHALL BE MADE OF CONCRETE OR OTHER MATERIAL APPROVED BY THE CITY ENGINEER (SEE NOTE 3).
- (3) THE UNIT IS TO BE LOCATED AWAY FROM TRAFFIC, IF POSSIBLE. IF INSTALLED IN TRAFFIC, THE UNIT MUST BE CAPABLE OF CARRYING H-20 LOADINGS.
- (4) NO WASTE FROM RESTROOMS SHALL FLOW THROUGH INTERCEPTOR.
- (5) ALL WASTE SHALL ENTER THE INTERCEPTOR THROUGH THE INLET PIPE ONLY.
- ig(6ig) structure shall be installed to allow access for maintenance or inspection at all times.
- 7 ALL SURFACE WATER MUST DRAIN AWAY FROM THE SAMPLING BOX AND INTERCEPTOR TO EXCLUDE ANY SURFACE DRAINAGE.
- 8 INSPECTION COVERS SHALL BE BROUGHT TO GRADE TO PERMIT VISUAL INSPECTION OF INTERNAL FITTINGS, WITH RISERS AS REQUIRED.

