



APPROVED BY:

DATE: 11/15/04

DIRECTOR OF TRANSPORTATION  
 GEORGE A. JOHNSON, RCE 42328

COUNTY OF RIVERSIDE

**CURB OUTLET**

REVISIONS	REV.	BY:	APR'D	DATE	REV.	BY:	APR'D	DATE
2-90, 11-04	1				4			
	2				5			
	3				6			

STANDARD NO. 308 (1 OF 2)

1. CONCRETE SHALL BE CLASS "A" WHEN STRUCTURE IS TO BE CONSTRUCTED WITHIN THE LIMITS OF A PROPOSED SIDEWALK OR IS CONTIGUOUS TO SUCH SIDEWALK, THE TOP OF THE STRUCTURE SHALL BE POURED MONOLITHIC WITH THE SIDEWALK, USING THE SAME CLASS OF CONCRETE AS IN THE SIDEWALK.
2. DIMENSIONS SHALL BE AS FOLLOWS UNLESS OTHERWISE SPECIFIED ON THE PLAN:  
 A - B = 5'  
 C<sub>1</sub> - D<sub>1</sub> = 3'  
 E - F = 5'  
 W = 3'
3. FLOOR OF STRUCTURE SHALL BE GIVEN A STEEL-TROWELED FINISH AND CONSTRUCTED ON A STRAIGHT GRADE FROM BACK OF STRUCTURE TO GUTTER FLOW-LINE AT POINT A. THE V-SECTION SPECIFIED FOR INVERT SHALL EXTEND FROM PIPE OUTLET TO A POINT 3' FROM THE GUTTER, FROM WHICH POINT THE INVERT SHALL BE WARPED TO JOIN THE GUTTER FLOW-LINE AT THE STRUCTURE.
4. REINFORCING STEEL BARS SHALL BE 1" FROM BOTTOM OF THE SLAB.
5. SURFACE OF ALL EXPOSED CONCRETE SHALL CONFORM TO EXISTING OR PROPOSED CURB AND WALK ADJACENT TO THE STRUCTURE.
6. CORRUGATED METAL FORMS SHALL NOT BE USED FOR SUPPORTING THE TOP SLAB.
7. TOP OF STRUCTURE SHALL SLOPE 2% TOWARD CURB EXCEPT WHEN OTHERWISE SHOWN ON PLAN OR TO FIT EXISTING SIDEWALK.
8. TRANSITION FROM PIPE TO STRUCTURE, IF REQUIRED, TO BE IN BACK OF SIDEWALK. DIMENSIONS OF TRANSITION SHALL BE SPECIFIED ON THE PLAN.
9. WHEN ABUTTING SOIL HAS A HIGH SULFATE CONTENT, SPECIAL CONSIDERATIONS ARE REQUIRED SEE SPECIFICATIONS (SECTION 16.04).

APPROVED BY: _____  <div style="text-align: right;">DATE: 11/15/04</div> _____ DIRECTOR OF TRANSPORTATION GEORGE A. JOHNSON, RCE 42328					COUNTY OF RIVERSIDE  <b>CURB OUTLET</b>				
REVISIONS		REV.	BY:	APR'D	DATE	REV.	BY:	APR'D	DATE
02-90, 11-04		1				4			
		2				5			
		3				6			
STANDARD NO. 308 (2 OF 2)									