



NOTES:

1. GROOVED COUPLING AND CAP SHALL BE VICTAULIC TYPE 77 AND 60, RESPECTIVELY OR APPROVED EQUAL.
2. TOP SLAB AND MANHOLE FRAME & COVER SHALL BE SET FLUSH WITH IMPROVED FINISHED GROUND OR 6" ABOVE UNIMPROVED GROUND, UNLESS OTHERWISE DIRECTED BY OWNER.
3. BOND JOINTS PER STD DWG 902.
4. COAT PER SPECIFICATIONS.
5. EPOXY COATING SHALL BE TNEMEC SERIES 80 WITH 10 MILS MDFT OR APPROVED EQUIV., UNLESS OTHERWISE SPECIFIED.
6. PIPE SHALL BE CEMENT MORTAR LINED AND COATED AND ADDITIONALLY COATED SIMILAR TO MAINLINE PIPE COATING SYSTEM. COATING(S) SHALL EXTEND TO BACK OF FLANGES AND TO GROOVED COUPLING.

REVISION	DATE	BY	DESCRIPTION	CALLEGUAS MUNICIPAL WATER DISTRICT	STANDARD DRAWINGS	DWG NO
5	08/06	P&I	GENERAL		8" BLOWOFF FOR WSP OR CCP - DISCHARGE TO STORM DRAIN OR ARROYO	501A
6	11/06	P&I	GENERAL			
7	12/06	P&I	GENERAL			
Susan Mulligan <small>Digitally signed by Susan Mulligan DN: cn=Susan Mulligan, c=US Date: 2006.12.11 09:56:17 -08'00'</small> APPROVED MANAGER OF ENGINEERING				THOUSAND OAKS CALIFORNIA		