


NOTES:

1. All concrete shall be Class 560-B-3250 per Standard Specifications for Public Works Construction. (GREEN BOOK)
2. The curb opening shall be as shown on plans, but not less than 4 feet for Type 1, 10 feet for Type 2.
3. Install step when required, per Standard Detail 2-003.0 and 2-003.1.
4. Connector pipe shall be placed on the back or side wall as shown in plans, to be clear of future drop inlet filter baskets.
5. Provide 3 inch radius rounded edge at pipe inlet.
6. The width of gutter depression shall be 4 feet unless otherwise shown on plans.
7. Manhole frame and cover shall be Alhambra Foundry A-1530B unless otherwise specified in plans.
8. Top slab surface shall be a light broom finish.
9. See Standard Detail 2-003 for drop inlet throat and step detail.
10. Gutter depression shall be Type A, Standard Detail 2-004 unless otherwise specified in plans.
11. Steel reinforcing bars in the top slab shall be #4 @12 inches On Center.
12. Wall thickness (T) and reinforcing requirements shall be per Table A, Std. Det. 2-001.0 & 2-002.0
13. Fugitive pigment curing seal shall be applied to all exposed surfaces immediately after finishing.
14. Aggregate base shall be placed 6 inches deep and compacted to 95% minimum relative compaction on undisturbed native soil before placing concrete.
15. Manhole shall be set 6 inches from inside wall of inlet.
16. All interior walls, floor, and top shall be sacked and patched upon completion.

REVISED	DATE	APPROVED	CITY OF SANTA BARBARA - PUBLIC WORKS DEPARTMENT	STANDARD DETAIL
			DROP INLET - NOTES	2-002.1-06
		PUBLIC WORKS DIRECTOR		
		1/21/07		
		DATE		