



THE MANHOLE BASE SHALL BE:

1. CLASS B CONCRETE POURED AGAINST UNDISTURBED EARTH, OR:
2. A PRECAST BASE WITH GASKETED JOINTS, PLACED ON 6" MINIMUM A.B., COMPACTED TO 95% RELATIVE DENSITY.

A	B	C	NOTES
M.H. DIA. 36"	3 1/2"	12"	MANHOLE FOR CONNECTION OF PRIVATE LINE TO PUBLIC MAIN WHEN SHOWN ON PLANS.
M.H. DIA. 48"	4"	30"	MANHOLE SHALL BE USED UNLESS OTHERWISE SPECIFIED.
M.H. DIA. 60"	-	-	DIMENSIONS IN ACCORDANCE WITH A.S.T.M. C-478-70 AS AMENDED.

REVISION	BY	DATE	APP. BY COUNCIL

CITY OF CHICO

STANDARD PLAN

DRAWN BY: GL DATE: 10/05
 CHECKED BY: MJ SCALE: NONE
 APPROVED: [Signature]
 DIRECTOR OF ENGINEERING

STORM DRAIN AND
 SANITARY SEWER MANHOLE

NO.
 S-10

SHEET 1 OF 2