

NOTES

1. CONNECTOR PIPE

LOCATE PIPE AS INDICATED ON SHEET 1.

2. CONCRETE

FLOOR OF BASIN SHALL SLOPE FROM ALL WALLS TO THE OUTLET AND SHALL BE GIVEN A STEEL TROWELED SURFACE FINISH.

3" (75 mm) THICK CONCRETE ENCASEMENT SHALL BE USED IN LIEU OF 6" (150 mm) THICK CONCRETE ENCASEMENT WHEN REQUIRED BY SPPWC 332 OR 334.

3. GENERAL

GRATING AND BASIN ARE NOT DESIGNED FOR VEHICULAR TRAFFIC AND SHALL NOT BE USED IN LOCATIONS WHERE SUCH TRAFFIC WILL OCCUR.

EMBED UTILITY BOX 1/2" (15 mm) INTO CONCRETE COLLAR. SEAL PIPE SLOTS IN UTILITY BOX WALLS WITH CONCRETE.

4. THE FOLLOWING SPPWC ARE INCORPORATED HEREIN:

332 JUNCTION STRUCTURE PIPE TO PIPE (INLET I.D. \leq 24" (600 mm))

334 JUNCTION STRUCTURE PIPE TO BOX (INLET I.D. \leq 30" (750 mm))