



NOTES:

1. FABRICATED EXTENSION STEM REQUIRED IF VALVE NUT IS MORE THAN 36" BELOW FINISHED GRADE.
2. GATE VALVE TO BE MUELLER, M&H (RESILIENT SEAT) OR APPROVED EQUAL
3. ANCHOR BLOCKS SHALL BE 450-C-2000 CLASS CONCRETE. CONCRETE SHALL BE POURED AGAINST UNDISTURBED SOIL.
4. VALVE CAN LID TO BE PAINTED DUNN EDWARDS OCEAN BLUE #S8009, TWO(2) COATS.

**CITY OF COLTON
WATER/WASTEWATER DEPARTMENT**

**TYPICAL GATE VALVE
ASSEMBLY**

DATE: MAY 2006	SCALE: N.T.S.	DWG. NO. 704
DWN BY: _____	REV: S.M.H	
APP'D BY: _____	DIRECTOR	