

NOTES:

- 1. UNLESS OTHERWISE SPECIFIED OR NOTED, STEP MAY BE ANY TYPE SHOWN.
- 2. STEPS SHALL BE STEEL CONFORMING TO ASTM A 307 AND SHALL BE GALVANIZED AFTER FABRICATION. IF STAINLESS STEEL STEPS ARE SPECIFIED OR CALLED FOR ON PLANS, THE MATERIAL SHALL CONFORM TO ASTM A 276, 300 SERIES.
- 3. UNLESS OTHERWISE NOTED ON DRAWINGS OR STANDARD PLANS FOR SPECIFIC STRUCTURES:

D=7"

E=6" OR T"-1" WHICHEVER IS LESS

S=16" MAXIMUM, EVENLY SPACED

- 4. BOTTOM STEP SHALL BE MAXIMUM OF 2 FEET ABOVE FLOOR OR SHELF.
- 5. TYPES 1 AND 2 STEPS MAY BE CAST IN PLACE OR PLACED IN THE CENTER OF 1 1/2" MINIMUM DIAMETER DRILLED OR FORMED HOLES AND SET WITH HIGH-STRENGTH (6000 PSI MIN.), NON-SHRINK GROUT. TYPE 3 STEP SHALL BE CAST IN PLACE.

REVISIONS	CITY OF LONG BEACH, CALIFORNIA	STANDARD
NO. DATE	DEPARTMENT OF PUBLIC WORKS	PLAN NO.
1	CTECL CTED	
2	STEEL STEP	615
3	APPROVED BY: Edward Juk DATE: 6-26-89	SHEET
4	CITY ENGINEER R.E. No. 24233 EX. DATE 12-31-89	2_OF_2