



**NOTES:**

1. STORM DRAIN CLEANOUT SHALL BE CONSTRUCTED OF 560-C-3250 CONCRETE.
2. CLEARANCE FROM I.D. OF PIPE TO CLEANOUT WALL SHALL BE 4" MIN.
3. APPROVED PRECAST CONCRETE MANHOLE SHAFT RINGS WILL BE ACCEPTED IN LIEU OF CAST-IN-PLACE SHAFT.

CITY OF CHINO HILLS

CHRIS VOGT  
CITY ENGINEER

STORM DRAIN  
CLEANOUT

207