


PLAN



SECTION A-A

NOTES

1. CAST IRON SHALL CONFORM TO A.S.T.M. SPECIFICATION A-48-64 CLASS 30 MINIMUM.
2. INSIDE DIAMETER OF TOP EDGE OF FRAME SHALL NOT EXCEED A DIMENSIONAL TOLERANCE OF $\pm 1/16$ INCH.
3. ALL FILLET RADI 1/8 INCH UNLESS OTHERWISE NOTED.

LONG BEACH WATER DEPARTMENT

MANHOLE FRAME

DESIGNED BY

CHECKED BY JUNIER

DATE 5-25-89

SCALE NONE

SUPERSEDES DWG. NO.

S-SD-II

DRAWN BY GONZALEZ

RECOMMENDED

[Signature]
 JUNIOR ENGINEER C.E. NO. 18113

APPROVED

[Signature]
 GENERAL MANAGER C.E. NO. 18644

SHEET

2 OF 4

WDS-503