



Longitudinal bars shall extend the full length of gutter.

NOTES:

1. Formed steel plate, A-3911-G anchors shall be factory-installed.
2. Protection bar, A-1565
3. Bar end anchors, A-1577
4. Protection bar support bolt(s), A-1574, spaced 21" apart (Max.)
5. Steps are required when depth exceeds 4' and shall be steel-reinforced copolymer poly-propylene, M-A industries PS2-PFS, or equal.
6. Manhole cover and frame, Phoenix P-1067, Alhambra A-1530, or approved equal placed adjacent to back wall near outlet pipe.
7. Curb height (less 1 1/2", matching standard gutter lip)
8. Curb opening width shall not be less than 3'-6" and may only be increased in 3'-6" increments.
9. Gutter construction adjacent to existing A.C. Paving shall include sawcutting, removal, and replacement of A.C. Paving 24" Min. from edge of new gutter, 2" thicker than existing (5" Min.).
10. Wing joint must be located at least 6' from curb return.
11. Concrete shall be Class 520-C-2500 (5 1/2 sack, 3/4" aggregate min.)

SECTION A-A

CITY OF ARROYO GRANDE - ENGINEERING DEPARTMENT

CURB OPENING CATCH BASIN

ISSUE DATE:
APR 1, 2005

Don Spagnolo, P.E.
Director of Public Works/City Engineer
L.C.E. No. 42993

STANDARD PLAN

300-AG

Sheet 1 of 1